



LEAD IN POTABLE WATER SCREENING REPORT

INVESTIGATION FOR: Andrew Gamper
Waldwick Board of Education
155 Summit Avenue
Waldwick, NJ 07463

SITE INVESTIGATED: Traphagen Elementary
155 Summit Avenue
Waldwick, NJ 07463

ASSESSMENT BY: Kyle Brown
Omega Environmental Services, Inc.
280 Huyler Street
South Hackensack, NJ 07606

INVESTIGATION
CONDUCTED: 4/25/17

DATE OF REPORT: 5/16/17

(Omega Project # 17-27015A)

TABLE OF CONTENTS

EXECUTIVE SUMMARY/PROJECT OVERVIEW

- 1. RESULTS TABLE**
- 2. SAMPLING METHODOLOGY**
- 3. DISCUSSION OF RESULTS**
- 4. RECOMMENDATIONS**

Appendices:

A. Laboratory Analytical Reports

EXECUTIVE SUMMARY:

The Waldwick Board of Education requested lead in water testing of potable water outlets at Traphagen Elementary, 155 Summit Avenue, Waldwick, NJ 07463.

Previous Testing

No information related to previous testing was available.

Recent Testing (4/25/17)

In order to assess the building water outlets a full testing of all potable outlets was performed on April 25, 2017.

Reportedly the outlets were not flushed or used on the day of testing.

First draw samples were collected of 33 water fountains and sinks.

Results of most first draw samples analyzed were below the Lead and Copper Rule action level of 15 ppb. Two first draw samples were above 15 ppb.

See Section 3 Discussion of Results

1 RESULTS TABLE:

Sample #	Location	1st draw (FD)	Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
1	Gym/Café (Left)	FD	1.22	15
2	Gym/Café (Right)	FD	ND	15
3	Kitchen (Café)	FD	9.25	15
4	Building 11 E	FD	7.53	15
5	Building 11 W	FD	6.58	15
6	Building 11 S	FD	7.64	15
7	Building 1 N	FD	3.41	15
8	Building 1 S	FD	1.62	15
9	Building K W	FD	2.20	15
10	Building K Center	FD	3.13	15
11	Building K E	FD	ND	15
12	Building 2 S	FD	3.59	15
13	Building 2 N	FD	3.46	15
14	Building 3 N	FD	4.83	15
15	Building 3 S	FD	4.71	15

16	Building 4 N	FD	ND	15
17	Building 4 S	FD	ND	15
18	Nurse Off.	FD	31.6	15
19	Main office	FD	21.9	15
20	Resource Building	FD	2.11	15
21	Building 5 S	FD	7.68	15
22	Building 5 N	FD	Not Sampled	15
23	Building 6 N	FD	1.68	15
24	Building 6 S	FD	1.95	15
25	Building 7 N	FD	1.28	15
26	Building 7 S	FD	1.62	15
27	Building 8 S	FD	2.96	15
28	Building 8 N	FD	2.44	15
29	Building 10 N	FD	1.52	15
30	Building 10 S	FD	2.17	15
31	Building 9 S	FD	3.10	15
32	Building 9 N	FD	2.31	15
33	Board office	FD	4.73	15
34	Blank	FD	ND	15

⁽¹⁾ EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

FL – Flush Sample (30 sec)

ND – Indicates that the analyte was not detected at the reporting limit

2 SAMPLING METHODOLOGY:

First Draw Samples - Without allowing any water to spill until sample collection, samples were collected with a relatively slow flow rate in 250 mL bottles prepared with Nitric Acid (HNO₃) as a preservative.

The samples were packaged in a cooler and shipped to EMSL Analytical, Inc, Cinnaminson, NJ for total lead in potable water analysis (method E200.8 IOC).

3 DISCUSSION OF RESULTS:

Two first draw sample results were above 15 ppb.

4 RECOMMENDATIONS:

Short term:

- Take any outlets with elevated results out of service.
- Conduct further evaluation and testing of outlets with elevated results.

Long Term:

- If additional testing shows similar results (first draw results above 15 ppb) consider replacing the spout of the fountains (may contain brass, adding to lead levels), installing filters (if practical), or fixture replacement.
- Repeat full building testing on an annual basis. Generally this should be performed in August prior to the start of the school season.
- Develop a Lead in Water Management Plan in accordance with the 2006 EPA 3Ts for Reducing Lead in Drinking Water in Schools.

A. Lead in Water Laboratory Reports



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Michael Levay
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

5/11/2017

Phone: (201) 489-8700
Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/28/2017. The results are tabulated on the attached data pages for the following client designated project:

17-27015A

The reference number for these samples is EMSL Order #011703333. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703333

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 04/28/17 8:30 AM

Project: 17-27015A

Analytical Results

Client Sample Description 1 Gym/Cafe(L) FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.22	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 2 Gym/Cafe(R) FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 3 Kitchen (Cafe) FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.25	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 4 Bldg 11E FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.53	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 5 Bldg 11W FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.58	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 6 Bldg 11S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.64	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 7 Bldg 1N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.41	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 8 Bldg 1S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703333

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 04/28/17 8:30 AM

Project: 17-27015A

Analytical Results

Client Sample Description 8 Bldg 1S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.62	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 9 Bldg K FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.20	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 10 Bldg K Center FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.13	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 11 Bldg K E FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 12 Bldg 2 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.59	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 13 Bldg 2 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.46	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 14 Bldg 3 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.83	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 15 Bldg 3 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead							

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703333

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 04/28/17 8:30 AM

Project: 17-27015A

Analytical Results

Client Sample Description 15 Bldg 3 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.71	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 16 Bldg 4 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 17 Bldg 4 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 18 Nurse Off. FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	31.6	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 19 Art Room FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.9	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 20 Resource BI FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.11	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 21 Bldg 5 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.68	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 23 Bldg 6 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703333

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 04/28/17 8:30 AM

Project: 17-27015A

Analytical Results

Client Sample Description 23 Bldg 6 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.68	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 24 Bldg 6 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.95	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 25 Bldg 7 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.28	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 26 Bldg 7 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.62	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 27 Bldg 8 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.96	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 28 Bldg 8 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.44	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 29 Bldg 10 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.52	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 30 Bldg 10 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
--------	-----------	--------	----	-------	-----------	---------	---------------	---------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011703333

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 04/28/17 8:30 AM

Project: 17-27015A

Analytical Results

Client Sample Description 30 Bldg 10 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 31 Bldg 9 S FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.10	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 32 Bldg 9 N FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.31	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 33 Board Office FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.73	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Client Sample Description 34 Blank FD **Collected:** 4/25/2017 **Lab ID:** 011703333-0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	5/3/2017	EG	5/5/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):
011703333

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077

Report To Contact Name: Michael Levey	Bill To Company: Omega Environmental
Company Name: Omega Environmental	Attention To: Accts Payable
Street: 280 Huyler Street	Street: 280 Huyler Street
City: S. Hackensack	City/State/Zip: S. Hackensack, NJ 07606
State: NJ	Phone: 201.489.8700
Zip: 201.342.5412	Fax: 201.342.5412
Project Name: 17-27015A	Email Results To: lab@omega-env.com [US State Samples Collected: NJ]
Number of Samples in Shipment: 3	Date of Shipment: <i>4/25/17</i>
Standard Turnaround Time: <input checked="" type="checkbox"/> 2 Weeks <input type="checkbox"/> 3 Weeks	Sampler Signature: <i>Michael Levey</i>

Client Sample ID	Comp	Grab	Date/Time	Matrix				Preserv.	List Test(s) Needed	Comments
				W=Water	S=Soil	A=Air	O=Other			
1 Gym/Café (L) FD	X	X	4/25/17	DW				2	X	
2 Gym/Café (R) FD	X	X	4:50	DW				2	X	
3 Kitchen (café) FD	X	X		DW				2	X	
4 Bldg 11 E FD	X	X		DW				2	X	
5 Bldg 11 W FD	X	X		DW				2	X	
6 Bldg 11 S FD	X	X		DW				2	X	
7 Bldg 1 N FD	X	X		DW				2	X	
8 Bldg 1 S FD	X	X		DW				2	X	
9 Bldg KW FD	X	X		DW				2	X	
10 Bldg K Center FD	X	X		DW				2	X	
11 Bldg KE FD	X	X		DW				2	X	
12 Bldg 2 S FD	X	X		DW				2	X	
13 Bldg 2 N FD	X	X		DW				2	X	
14 Bldg 3 N FD	X	X		DW				2	X	
15 Bldg 3 S FD	X	X		DW				2	X	
16 Bldg 4 N FD	X	X		DW				2	X	
17 Bldg 4 S FD	X	X		DW				2	X	
18 Nurse Off. FD	X	X		DW				2	X	

Released By (Signature) <i>Michael Levey</i>	Date & Time 4/25/17 8:55 AM	Received By <i>AM COURIER</i>	Date & Time 4/27/17 7:10 pm
--	---	---	---

Please indicate reporting requirements: Results only Results and QC Reduced Deliverables Disk Deliverables Other

Instructions or Comments:
Rec'd in file 22.1 4/28/17 08:30





EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):
011703333

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077

Report To Contact Name: Michael Levay	Bill To Company: Omega Environmental
Company Name: Omega Environmental	Attention To: Accts Payable
Street: 280 Huyler Street	Street: 280 Huyler Street
City: S. Hackensack	City/State/Zip: S. Hackensack, NJ 07606
Phone: 201.489.8700	Phone: 201.489.8700
Fax: 201.342.5412	Fax: 201.342.5412
Project Name: 17-27015A	US State Samples Collected: NJ
Number of Samples in Shipment: 33	Sampler Signature: <i>[Signature]</i>
Email Results To: lab@omega-env.com	Date of Shipment: 1/01/1900

Standard Turnaround Time: 2 Weeks 3 Weeks 4 Weeks 5 Weeks 6 Weeks 7 Weeks 8 Weeks 9 Weeks 10 Weeks 11 Weeks 12 Weeks

Following TATs are subject to Lab Approval: 1 Week 2 Days 3 Days 4 Days 5 Days 6 Days 7 Days 8 Days 9 Days 10 Days 11 Days 12 Days

Client Sample ID	Comp	Grab	Date/Time	Matrix				Preserv.	List Test(s) Needed			Comments		
				W=Water	S=Soil	A=Air	O=Other		1=HCL	2=HNO3	3=H2SO4		O=Other	ICP/MS
19	40-Metro office	FD	4/12/17	DW				2						19
20	Resource BIFD		4:50	DW				2						20
21	Bldg 5 S	FD		DW				2						21
22	Bldg 5 N	FD		DW				2						22
23	Bldg 6 S	FD		DW				2						23
24	Bldg 6 N	FD		DW				2						24
25	Bldg 7 N	FD		DW				2						25
26	Bldg 7 S	FD		DW				2						26
27	Bldg 8 S	FD		DW				2						27
28	Bldg 8 N	FD		DW				2						28
29	Bldg 10 N	FD		DW				2						29
30	Bldg 10 S	FD		DW				2						30
31	Bldg 9 S	FD		DW				2						31
32	Bldg 9 N	FD		DW				2						32
33	Board office	FD		DW				2						33
34	Blank	FD		DW				2						34
00				DW				2						00
00				DW				2						00

Released By (Signature): *[Signature]* **Date & Time:** 4/25/17 8:55 AM

Please indicate reporting requirements: Results only Results and QC Reduced Deliverables Disk Deliverables Other

Instructions or Comments: